

BOTTOM BAR LOCK	
TYPE	OPERATION
SLIDE BOLT	<input type="checkbox"/> INSIDE <input type="checkbox"/> OUTSIDE
CYLINDER	<input type="checkbox"/> <input type="checkbox"/>
NO LOCKING	<input type="checkbox"/>

FIRE DOOR || STD MNT H MTR || BTWJAMB


- NOTES:
1. GENERAL SPECIFICATIONS SEE SHEET 1.
 2. APPROX. WT. OF DOOR IS _____ WT LBS.
 3. PROVIDE ADEQUATE CLEARANCE FOR WIRING MOTOR.
 4. ELECTRICAL INFORMATION:
VOLTAGE _____ PHASE _____
CONTROLLER NEMA 1 _____
CONTROL STATION NEMA 1 _____
PUSH BUTTON SURFACE MTD
KEY STATION FLUSH MTD

5. DOOR COMPANY ASSUMES THAT THE FIRE DOOR(S), THE WALL AND/OR MOUNTING CONDITIONS, ALONG WITH THE FASTENERS USED IN ATTACHING THE DOOR(S) TO THE STRUCTURE MEET WITH THE "AUTHORITY HAVING JURISDICTION'S" APPROVAL. FOR FURTHER REFERENCE CONSULT N.F.P.A. BULLETIN 80.

DIMENSIONS AND CLEARANCES AS NOTED BY ASTERISK (*) MUST BE FIELD CHECKED.
 VERIFIED BY: _____ ON: _____
 NO CANCELLATIONS OR RETURNS ON THIS ORDER:
 Signature: _____

MAKE	HAND	ARCH. MARK	DOOR MARK
	AS SHOWN		
	OPPOSITE		

NO.	BY	DATE	REVISION
1			ORIGINAL DRAWING



JOB: _____
 CONTRACTOR: _____
 ARCHITECT: _____
 DISTRIBUTOR: _____
 DRAWING NO. _____ OF _____